

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009949.01-R5
DATE: 07/01/2009
CERTIFICATION PROGRAM: Structural
COMPANY: Eagan
CODE: 1537-1
REVISION DATE: 08/31/2017

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eagan Manufacturing, Inc. 620 Eagan Road Black Rock, AR 72415	"Fiberglass Out-Swing Single Door with Aluminum Fin Frame" Configuration: X (Opaque) Frame: W-1588mm(62.5") H-2102mm(82.75") Panel: W-1537mm(60.5") H-2032mm(80")

SPECIFICATION	PRODUCT RATING
ASTM E330-02	Design Pressure: +20/-20 psf

Product Tested By: Certified Testing Laboratories
Report No: CTLA-1980W-4
Expiration Date: **July 31, 2022**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122