

FLIPPIN SCHOOL DISTRICT
NORTH CENTRAL ACCREDITED
KELVIN HUDSON, SUPERINTENDENT

September 18, 2017

- All products bid should be of equal or greater quality than products describes herein and / or in RFP
- Prices should include all shipping, installation.
- Bidder must state estimated time of delivery and install.

INVITATION TO BID

Flippin School District is accepting bids for outdoor, walk-in freezer and cooler.

Venders interested in a bid package may contact:
Kelvin Hudson, Superintendent
kelvinhudson@flippinschools.net

Deadline: All bids due no later than 2:00 p.m. September 29, 2017

Sealed Bid Opening: September 29, 2017 at 2:00 p.m.

Contact: Kelvin Hudson
Administration Office
210 Alford St.
Flippin, AR. 72634
Ph. 870 453-2270

The district reserves the right to accept or reject all or part of a bid or any or all bids, to waive minor technicalities, and to award the bid to best serve the interest of the District.

Flippin School District
210 Alford St.
Flippin, AR 72634

Thank you

Kelvin Hudson, Superintendent
Flippin School District

FLIPPIN SCHOOL DISTRICT

NORTH CENTRAL ACCREDITED

KELVIN HUDSON, SUPERINTENDENT

Outdoor, Walk-in cooler and freezer will sit on an approximately 16' x 13' pad. Both units will be approximately 8' x 13' in size. Awarded bidder will take exact measurements prior to fabrication.

Both units should meet or exceed industry DOE standards est. in 2009
#10CFR431.306

At a minimum, boxes should consist of:

- pre-fab wall and floor panels
- flush mount doors
- self-closing hinges
- hydraulic closers
- illuminated interiors
- exterior locking hasp for pad lock
- roof membrane, mounting hardware, and roof cap
- door heaters
- door curtains
- freezer should hold 0 degrees Fahrenheit even though the unit is outdoors
- cooler should hold 33 degrees Fahrenheit even though the unit is outdoors
- defrost heaters
- defrost timers
- fan cycle switch on condenser
- outdoor cover for condenser
- both units should utilize R404A refrigerant
- full disclosure of any and all warranties should be clearly stated

Please contact Kelvin Hudson if you would like additional information and/or would like to look at the site prior to bidding. Units will be enclosed on 3 sides by brick and mortar with an exposed front and top.